

CORE STRUCTURES

STRUCTURAL CONSULTING ENGINEERS

STRUCTURAL STABILITY CERTIFICATE

Certificate No. : 1009-SC

1. Name & Address of Building : Jai Rani Public School, Thodupuzha
Building No. 514/A , Ward 34
in Survey No. 270/4B, 270/4B, 270/7C
Thodupuzha , Thodupuzha Village,
Thodupuzha Taluk, Idukki District.

2. Name & Address of Owner : Provincial Procurator, St. Marys Province,
Nirmala Bhavan, Jai Rani School
Thodupuzha, Idukki District

I hereby certify that I have inspected the above referred school building and examined the various parts. The said building is Cellar + Ground + 2 storyed with floor area of 1197.88 sqm consisting of Eleven Classrooms, Three Staff Room, Gents and Ladies Toilets, Car Porch, Courtyard, Lobby Areas, Lift and Staircase. It is a 9 year old building with RCC Framed structure for C+G+2 Floors. No visible cracks or defects can be seen in the building. The Structural fitness certificate issued by the Engineering firm(Licensee and Architect of this building) at the completion of the building is attached herewith.

I am of the opinion that no damage has occurred to the said building and the building is structurally fit to be used for educational purposes.

Sincerely



MATHEW THOMAS, B.Tech, M.Tech
Structural Engineer
CHARTERED ENGINEER (INDIA)
Reg. No: AM1986581



Date: June 09, 2025
Place: Cherpunkal

For **Core Structures**
Mathew Thomas
Structural Engineer